


KUSAM-MECO

DIGITAL INSULATION TESTER

MODEL KM - 369
KM - 360



Model No	KM 369	KM 360
Functions		
Rating voltage	100V/250V/500V/1000V	100V/500V/1000V/2500V
Resistance	0~2000M	0~20,000M
Minimum Division	1M	10M
Short current (mA)	1.5mA	1.5mA
V AC	----	----
Low Battery Test	✓	✓
Insulation Resistance	500M (1000V)	500M (1000V)
Withstand Voltage	AC 3kV 50Hz 1min	AC 3kV 50Hz 1min
Operating Temperature & Humidity	0~40°C 85%RH	0~40°C 85%RH
Max. Display	1999	1999

KUSAM-MECO

An ISO 9001:2000 company

Industrial Supply Syndicate

Office : 54, Ezra Street, Kolkata - 700 001, India.

Tel. : (033) 3291 6080, 22356676 Fax : (033) 3022 2923

E-mail : info@industrialindia.com, Website : www.industrialindia.com